

ADDENDUM #1 TO BID SPECIFICATIONS FOR EMERGENCY GENERATOR FOR THE
STILLWATER TOWNSHIP MUNICIPAL BUILDING

December 11, 2015

Propane Tank: The propane tank is changed from 500 gallons to a 1000 gallon vapor propane tank.

Location: The location is changed to the east end of the building with the generator a minimum of five feet from end of building and the propane tank a minimum of 25 feet from the end of building (three pictures attached of location)

The meter and transfer switch will be mounted to the east end of building and two inch (2") conduit with wire will be used to connect to the main electrical panel on top of drop ceiling approximately 60 feet.